

## TITLE 326 AIR POLLUTION CONTROL BOARD

### DRAFT RULE #06-121(APCB)

### DIGEST

Amends 326 IAC 6.5-7-13 to identify the source as Holy Cross Services Corporation (Saint Mary's Campus). Effective 30 days after filing with the Secretary of State.

### HISTORY

IC 13-14-9-8 Notice and Notice of First Hearing: May 1, 2006, Indiana Register (29 IR 2684)

Date of First Hearing: June 7, 2006

### 326 IAC 6.5-7-13

### DRAFT RULE

SECTION 1. 326 IAC 6.5-7-13 AS AMENDED AT 29 IR 476, SECTION 1, IS AMENDED TO READ AS FOLLOWS:

#### 326 IAC 6.5-7-13 Holy Cross Services Corporation (Saint Mary's Campus)

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 13. (a) **Holy Cross Services Corporation** (Saint Mary's **Campus**) in St. Joseph County shall meet the following emission limits:

Source	NEDS Plant ID	Point Input ID	Process	Emission Limits		
				tons/yr	lbs/million Btu	grains/ds cf
<b>Holy Cross Services Corporation</b> (Saint Mary's <b>Campus</b> ) Natural gas fired with fuel oil No. 2 as a backup	03	56P	Boiler No. 1 gas fired 31.5 MMBtu/Hr.	3.9	0.014	
Natural gas fired with fuel oil No. 2 as a backup	01	54P	Boiler No. 2 gas fired 63 MMBtu/Hr.	3.9	0.014	
100% natural gas	02	55P	Boiler No. 3 gas fired 63 MMBtu/Hr.			

(b) Boiler No. 3, ~~at Saint Mary's~~, identified in subsection (a) as one hundred percent (100%) natural gas burner, shall burn only natural gas. (*Air Pollution Control Board; 326 IAC 6.5-7-13; filed Aug 10, 2005, 1:00 p.m.: 28 IR 3487; filed Oct 3, 2005, 10:00 a.m.: 29 IR 476*)